



Certified Return Receipt

THE LUBRIZOL CORPORATION  
P.O. BOX 158  
41 TIDAL ROAD  
DEER PARK, TX 77536-0158  
TELEPHONE: 713/479-2851

April 6, 2000

NWM-005-2000

Texas Natural Resource Conservation Commission  
Office of Water Management  
Self-reporting Section  
P.O. Box 13087  
Austin, Texas 78711-3087

RE: TNRCC Water Discharge Permit No. WQ000639

Attention: Representative

Please be informed that a recent water discharge from the Lubrizol Corporation- Deer Park Plant exceeded the limits of the above-referenced permit as follows:

<u>DATE</u>	<u>OUTFALL</u>	<u>PARAMETER</u>	<u>RESULT</u>	<u>LIMIT</u>
04/03/00	001	Flow, Daily Max.	1.840 Million Gal/Day	1.440 Million Gal/Day

The above flow exceedence was experienced due to 3.2 inches of rain during this period.

Lubrizol regrets any inconvenience this permit exceedence may have caused and the company remains committed to making every reasonable effort to assure compliance with the TNRCC water discharge permit requirements. Should you have any further questions, please contact me at (281) 479-2851.

Sincerely,  
THE LUBRIZOL CORPORATION

*John H. Garrett*  
John H. Garrett  
Works Manager, Deer Park Plant

JHG/nwm

9155473

